

## DIESEL GENERATOR DATA SHEET

### MG POWER DIESEL GENERATOR Cummins® powered Genset Model:MGC 200



\*Drawing above for illustration purposes only

#### I. GENERAL DATA

Prime Power	kW/kVA	200	250
Standby Power	kW/kVA	220	275
Frequency	Hz/rpm	50	1500
Voltage	V	400	230
Current	А	30	51
Connection	/	3P 4	IW/Y
Rated Power Factor	/	C	.8
Open Type (L×W×H)	mm	3000×11	.00×1920
Open Type(Weight)	kg	29	900
Silent Type (L×W×H)	mm	4200×15	00×2100
Silent Type(Weight)	kg	40	)50





Available for voltages 400/230V, 480/277V, 380/220V, 440/254V, 416/240V, 220/127V, 208/120V

■ All datas based on ISO 3046, altitude 100m (328ft), barometric pressure 100kPa (29.53inHg), air temperature 25°C (77°F), relative humidity 30%.

Please contact with YANAN engineer for correct generator capacity selection when the load application can't meet with the standard reference.

■ YANAN diesel generators comply with standards: ISO8528, ISO14000, ISO3046, GB755, BS5000, VDE0530, IEC34-1

#### **II. STANDARD CONFIGURATION**

Engine	Cummins, including air filters, fuel filters, oil filter, starting motor and charging alternator etc.			
Alternator	YANAN brushless AC alternator			
Radiator	Silent Type 50 $^\circ\!\mathrm{C}$ $$ $($ Open Type 40 $^\circ\!\mathrm{C}$ $) $ , fan protective shroud			
D	≤550KW: base mounted fuel tank, anti-vibration pads, battery holder			
Base Frame	$\geq$ 550KW: channel steel base frame, anti-vibration pads, battery holder			
Circuit Breaker	$\leq$ 63A: Micro Circuit Breaker (MCB) $>$ 63A $\leq$ 1250A: Molded case circuit breaker(MCCB) , $>$ 1250A: Air circuit breaker(ACB)			
Control System	DEEP SEA 6120			
Start Battery	Dry charged battery, available for 6 times starts under standard condition; connection cables.			
Installation Accessories	Bellow, Elbow and flange, Exhaust silencer, etc.			
Documents	Electric drawing, operation & maintenance manual, certification etc.			

#### III. OPTIONAL CONFIGURATION

Engine Accessories	$\diamond$ Heavy-duty air filter $\diamond$ Coolant heater $\diamond$ Lub oil heater $\diamond$ Fuel and Water Separator
Alternator And	$\Diamond$ Stamford $\diamond$ Leroy Somer $\diamond$ Marathon $\diamond$ Anti condensation heater $\diamond$ PMG
Accessories	◇High voltagekV
Cooling System	$\diamond$ 50 $^\circ C$ radiator $\diamond$ Heat exchanger + water cooling tower + External water circulation pumping system
	$\diamond$ Remote horizontal water tank system
Control System	$\Diamond$ AMF $\diamond$ Parallel $\diamond$ Practical type in low temperature environment $\diamond$ Control Screen Heater
control system	♦ Other (Comap、DEIF)
Circuit Breaker	$\Diamond$ 3/4 poles $\diamond$ Fixed/handcart type $\diamond$ Electric mechanism
Automatic Transfer Swtich	◇ATS cabinet
Start Battery	$\Diamond$ Nickel-cadmium battery $\Diamond$ Maintenance-free battery $\Diamond$ Power charger and selector
Start Battery	◇Charging current meter
External Fuel Tank	$\diamond$ 500L $\diamond$ 1000L $\diamond$ 1500L $\diamond$ 2000L $\diamond$ 2500L $\diamond$ 3000L $\diamond$ 4000L $\diamond$ 5000L
Others	

## DIESEL GENERATOR DATA SHEET

#### IV. ENGINE DATA

Engine Model	NT855-GA	Engine Power	254	kW
Aspiration	Turbocharged	Displacement	14	L
Туре	In-line	Bore×Stroke	140×152	mm
No. of Cylinders	6	Compression Ratio	15.0:1	
Governor Type	Electronic Governor	Rated Speed	1500	RPM

#### Fuel System

Prime Power Fuel Consumption	53.4	L/h	Standby Power Fuel Consumption	58.4	L/h
Fuel #	ASTM D975 I BS2869 1998		Injection System	PT	

#### Lubrication System

Lub Oil Capacity	38.6	L			
Lub #	API CF-4 15V	V40	Max.Temperature	121	°C

#### Coolant System

Coolant Capacity	66	L	Max. Top Tank Temp.	104	°C
Std. Thermostat (Modulating) Range	82-94	$^{\circ}\mathrm{C}$	Fan Drive Method	Shaft drive	
Cooling Fan Air Flow	420	m3/min			

#### Air Intake System

Combustion Air Flow	17.28/18.36	m3/min	Maximum Air Intake Restriction	3.7	kPa
Exhaust System					
Exhaust Gas Flow	39/41.4	m3/min	Max.Back Pressure	10	kPa
Exhaust Gas Temp	≤469	$^{\circ}\mathrm{C}$	Exhaust Pipe Size	φ127	mm

#### ■ Starting System

Start Mode	DC24V Electric start	Battery	2x150	Ah

All data is subject to change without notice, sorry for inform.

📾 C E 💷 🔄 CCS ISO9001 ISO14000 ISO18000 "93" intertek

## DIESEL GENERATOR DATA SHEET

#### V. ALTERNATOR DATA

Alternator Model	SLG274K	Rate Power	200/250	kW/kVA
PF.	0.8	Voltage	400/230	V
Phase	3	Frequency	50	Hz
Connection	3P 4W/Y	Bearing	1	
Winding Pitch	2/3	Proteccion Class	IP23	
Insulation Class	н	Efficiency	92%	
Tel. Influence	TIF: <50	Voltage Regulation	±1.0%	
Harmonic Coefficient	THF: <2%	AVR	AS440	
Voltage Adjust Scope	≥±5%	Excitation System	Self Excited	

#### VI. CONTROL SYSTEM DATA

#### Main feature

Electronic J1939 (CAN) and nonelectronic MPU and alternator sensing engine support for diesel, gas and petrol engines all in one variant. With a number of flexible inputs, outputs and protections, the modules can be easily adapted to suit a wide range of applications.

#### • Key Function

- ▲Utility voltage sensing ▲Generator/load powermonitoring (kW, kV A, kV Ar, pf)  $\blacktriangle$  Generator overload protection(kW)  $\blacktriangle$  3 engine maintenance alarms ▲ Efficient power save mode ▲ mains and generator closed via front panel ▲4 configurable DC outputs ▲4 configurable analog./digitalinputs ▲6 configurable digital inputs ▲Support for 0-10 V & 4-20 mAoil pressure sensors
- ▲ Configurable staged loadingoutputs ▲ Configurable remote start input
  - ▲CAN, MPU and alternator
  - speed sensing in one variant

  - ▲Engine speed protection
  - ▲Engine pre-heat
  - ▲ Multiple date and time scheduler
  - ▲Engine idle control for starting
  - &stopping
  - ▲ Fuel pump control
  - ▲ Battery voltage monitoring
  - ▲ Start on low battery voltage

#### MODEL DSE6120



DSE6120 MKIII

- ▲ Alternative configuration
- ▲ Alarm including common alarm, common
- electric and common shutdown
- ▲LCD and LED alarm indication
- ▲ Configurable event log (50)
- Heated display option available
- rightarrow For more information, please visit theofficial website

## DIESEL GENERATOR DATA SHEET

#### VI. WARRANTY POLICY

1. Guarantee for one year or 1000 hours (accord to whichever reach first) from ex-factory date. Refer to

《YANAN Diesel Generator Warranty Manual》 for more details.

2.Wearing parts( filters), incorrect man-made operation, maintenance failures are excluded from the warranty policy

#### VII. DRAWING (for illustration purposes only)

