

### DIESEL GENERATOR DATA SHEET

#### MG POWER DIESEL GENERATOR Cummins® powered Genset Model:MGC 460



\*Drawing above for illustration purposes only

#### I. GENERAL DATA

Prime Power	kW/kVA	460	575
Standby Power	kW/kVA	520	650
Frequency	Hz/rpm	50	1500
Voltage	V	400	230
Current	А	83	30
Connection	/	3P 4	W/Y
Rated Power Factor	/	0	.8
Open Type (L×W×H)	mm	3700×17	′50×2270
Open Type(Weight)	kg	46	500
Silent Type (L×W×H)	mm	5100×21	00×2500
Silent Type(Weight)	kg	65	500



Available for voltages 400/230V, 480/277V, 380/220V, 440/254V, 416/240V, 220/127V, 208/120V

■ All datas based on ISO 3046, altitude 100m (328ft), barometric pressure 100kPa (29.53inHg), air temperature 25°C (77°F), relative humidity 30%.

Please contact with YANAN engineer for correct generator capacity selection when the load application can't meet with the standard reference.

■ YANAN diesel generators comply with standards:ISO8528,ISO14000,ISO3046,GB755,BS5000,VDE0530,IEC34-1

#### **II. STANDARD CONFIGURATION**

Engine	Cummins, including air filters, fuel filters, oil filter, starting motor and charging alternator etc.			
Alternator	YANAN brushless AC alternator			
Radiator	Silent Type 50 $^\circ\!\mathrm{C}$ $$ (Open Type 40 $^\circ\!\mathrm{C}$ ) , fan protective shroud			
	≤550KW: base mounted fuel tank, anti-vibration pads, battery holder			
Base Frame	$\geq$ 550KW: channel steel base frame, anti-vibration pads, battery holder			
Circuit Breaker	$\leq$ 63A: Micro Circuit Breaker (MCB) $>$ 63A $\leq$ 1250A: Molded case circuit breaker(MCCB) , $>$ 1250A: Air circuit breaker(ACB)			
Control System	DEEP SEA 6120			
Start Battery	Dry charged battery, available for 6 times starts under standard condition; connection cables.			
Installation Accessories	Bellow, Elbow and flange, Exhaust silencer, etc.			
Documents	Electric drawing, operation & maintenance manual, certification etc.			

#### **III. OPTIONAL CONFIGURATION**

Engine Accessories	$\diamondsuit$ Heavy-duty air filter $\diamondsuit$ Coolant heater $\diamondsuit$ Lub oil heater $\diamondsuit$ Fuel and Water Separator				
Alternator And	$\Diamond$ Stamford $\Diamond$ Leroy Somer $\Diamond$ Marathon $\Diamond$ Anti condensation heater $\Diamond$ PMG				
Accessories	$\diamond$ High voltagekV				
Cooling System	$\diamond$ 50 $^\circ C$ radiator $\diamond$ Heat exchanger + water cooling tower + External water circulation pumping system				
	$\Diamond$ Remote horizontal water tank system				
Control System	$\Diamond$ AMF $\diamond$ Parallel $\diamond$ Practical type in low temperature environment $\diamond$ Control Screen Heater				
control system	♦Other (Comap、 DEIF)				
Circuit Breaker	$\Diamond$ 3/4 poles $\Diamond$ Fixed/handcart type $\Diamond$ Electric mechanism				
Automatic Transfer Swtich	◇ATS cabinet				
Start Battery	$\Diamond$ Nickel-cadmium battery $\Diamond$ Maintenance-free battery $\Diamond$ Power charger and selector				
Start Battery	♦ Charging current meter				
External Fuel Tank	$\diamond$ 500L $\diamond$ 1000L $\diamond$ 1500L $\diamond$ 2000L $\diamond$ 2500L $\diamond$ 3000L $\diamond$ 4000L $\diamond$ 5000L				
Others					

## DIESEL GENERATOR DATA SHEET

#### IV. ENGINE DATA

Engine Model	KTAA19-G6	Engine Power	570	kW
Aspiration	Turbocharged , Air-to-air Cooled	Displacement	19	L
Туре	In-line	Bore×Stroke	159X159	mm
No. of Cylinders	6	Compression Ratio	13.9:1	
Governor Type	Electronic Governor	Rated Speed	1500	RPM

#### Fuel System

Prime Power Fuel Consumption	132	L/h	Standby Power Fuel Consumption	145	L/h
Fuel #	ASTM D975 I BS2869 1998	No.2-D or 3 Class A1, A2	Injection System	PT	

#### Lubrication System

Lub Oil Capacity	50	L			
Lub #	API CF-4 15W	/40	Max.Temperature	121	°C

#### Coolant System

Coolant Capacity	118.5	L	Max. Top Tank Temp.	104	°C
Std. Thermostat (Modulating) Range	82-93	°C	Fan Drive Method	Shaft drive	
Cooling Fan Air Flow	840	m3/min			

#### Air Intake System

Combustion Air Flow	37.38/ 42.18 m3/min	Maximum Air Intake Restriction	3.7	kPa
Exhaust System				

Exhaust Gas Flow	111.6/119.1	m3/min	Max.Back Pressure	10	kPa
Exhaust Gas Temp	≤457	°C	Exhaust Pipe Size	φ150	mm

#### Starting System

Start Mode	DC24V Electric start	Battery	2x200	Ah

#### 🗐 🕻 🔍 🚭 CCS ISO9001 ISO14000 ISO18000 🖓 🛄 Intertek

## DIESEL GENERATOR DATA SHEET

#### V. ALTERNATOR DATA

Alternator Model	SLG354E	Rate Power	480/600	kW/kVA
PF.	0.8	Voltage	400/230	V
Phase	3	Frequency	50	Hz
Connection	3P 4W/Y	Bearing	1	
Winding Pitch	2/3	Proteccion Class	IP23	
Insulation Class	н	Efficiency	94.9%	
Tel. Influence	TIF: <50	Voltage Regulation	±1.0%	
Harmonic Coefficient	THF: <2%	AVR	AS440	
Voltage Adjust Scope	≥±5%	Excitation System	Self Excited	

#### VI. CONTROL SYSTEM DATA

#### Main feature

Electronic J1939 (CAN) and nonelectronic MPU and alternator sensing engine support for diesel, gas and petrol engines all in one variant. With a number of flexible inputs, outputs and protections, the modules can be easily adapted to suit a wide range of applications.

#### **Key Function**

- ▲ Utility voltage sensing ▲Generator/load powermonitoring (kW, kV A, kV Ar, pf)  $\blacktriangle$  Generator overload protection(kW)  $\blacktriangle$  3 engine maintenance alarms ▲Efficient power save mode ▲ mains and generator closed via front panel ▲4 configurable DC outputs ▲4 configurable analog./digitalinputs &stopping ▲6 configurable digital inputs ▲Support for 0-10 V & 4-20 mAoil pressure sensors
- ▲ Configurable staged loadingoutputs ▲ Configurable remote start input ▲CAN, MPU and alternator speed sensing in one variant ▲Engine speed protection ▲Engine pre-heat ▲ Multiple date and time scheduler ▲ Engine idle control for starting ▲Fuel pump control ▲ Battery voltage monitoring
  - ▲ Start on low battery voltage

MODEL DSE6120



DSE6120 MKIII

- ▲ Alternative configuration
- ▲Alarm including common alarm,common

electric and common shutdown

- ▲ LCD and LED alarm indication
- ▲ Configurable event log (50)
- ▲ Heated display option available

 $\cancel{T}$  For more information, please visit the

official website

## DIESEL GENERATOR DATA SHEET

#### M. WARRANTY POLICY

1. Guarantee for one year or 1000 hours (accord to whichever reach first) from ex-factory date. Refer to

 $\langle\!\!\!\langle \mathsf{YANAN} \: \mathsf{Diesel} \: \mathsf{Generator} \: \mathsf{Warranty} \: \mathsf{Manual} \:\!\!\rangle \;$  for more details.

2. Wearing parts( filters), incorrect man-made operation, maintenance failures are excluded from the warranty policy

#### M. DRAWING (for illustration purposes only)

